


SMA Inverter Restart Procedure




STEP 01

Turn off the "Inverter AC Isolator" located next to the inverter, OR the "Main Switch (Inverter Supply)" located in the main switchboard of the house or meter box.

Turn off the "PV Array DC Isolator" which is the black rotary switch located on the bottom of the inverter.

STEP 02



STEP 03

FOR A FEW MINUTES

ALL LED INDICATORS SHOULD BE OFF



STEP 04

Turn on the "PV Array DC Isolator" first, and then the "AC Isolator" second (Step 2 and then Step 1)

